



**District Level Water Quality Testing and Monitoring
Laboratory Uttarakhand Jal Sansthan, Collectrate
Campus, Rudrapur (U.S. Nagar)**

TEST REPORT

Name and Address of Organization/ Customer	Gurukul Academy, Sitarganj Road, Jhankat, khatima, Distt-U.S. Nagar		
Test Report ID	27A/UJS/DLWQTML/2025-26	Reporting Date	22.09.2025
		Sample Location	Sample-01 Ro
Product Description	Drinking Water	Sample Collected by	Customer
Reference Sample Identification:	DLWQTML/UJS/GUA-01		
Date of Start of Analysis:	19/09/2025		
Date of End of Analysis:	22/09/2025		
Date and Time of Sample Received:	19/09/2025 & 13:25		

SN	Parameters	Test Method	Results	Acceptable Limit As per (IS 0500:2012)	Permissible Limit (IS 10500:2012) in the Absence of alternative source
1	Total Coliform, MPN/ 100ml	APHA 23rd Ed.-9223-B	Absent	Absent	Absent
2	E. coli, MPN/ 100ml	APHA 23rd Ed.-9223-B	Absent	Absent	Absent

1. The results listed refer only to tested sample and applicable parameters.
2. This certificate is not be reproduced wholly or in parts promotional publicity or legal purpose without permission of authority of testing laboratory.
3. The samples will be destroyed after 15 days from the date of issue of test certificate, unless otherwise agreed with customer.
4. The results apply to the sample as received
5. The Laboratory is responsible for all the information provided in the report, except when information is provided by the customer

**** End of Report****


(Er. Mukesh Kumar)
Technical Manager
Review and Authorized By
District Water Quality Testing
Monitoring Laboratory
Uttarakhand Jal Sansthan, U.S. Nagar



**District Level Water Quality Testing and Monitoring
Laboratory Uttarakhand Jal Sansthan, Collectrate
Campus, Rudrapur (U.S. Nagar)**



TC-13345

TEST REPORT

Name and Address of Organization/ Customer	Gurukul Academy, Sitarganj Road, Jhankat, Khatima, Distt-U.S. Nagar		
Test Report ID	27/UJS/DLWQTML/2025-26	Reporting Date	22/09/2025
ULR No.	TC1334525000000027F	Sample Location	Sample-01, Campus RO
Product Description	Drinking Water	Sample Collected by	Customer
Reference Sample Identification:	DLWQTML/UJS/GUA-01		
Date of Start of Analysis:	19/09/2025		
Date of End of Analysis:	22/09/2025		
Date and Time of Sample Received:	19/09/2025 & 13:25		

SN	Parameters	Test Method	Result	Acceptable Limit As per (IS 10500:2012)	Permissible Limit (IS 10500:2012) in the Absence of alternative source
1.	pH at 25°C	IS 3025 (Part 11) 2022,	7.13	6.5 to 8.5	No Relaxation
2.	Total Dissolved Solids (TDS), at 180°C mg/L, Max	IS 3025 (Part 16), 2023	90	500	2000
3.	Turbidity, NTU, Max	IS 3025 (Part 10), 2023	0.36	1	5
4.	Total Alkalinity (as CaCO ₃), mg/L, Max	IS 3025 (Part 23), 2023	52	200	600
5.	Total Hardness (as CaCO ₃), mg/L, Max	IS 3025 (Part 21), 2009	52	200	600
6.	Calcium as Ca, mg/l	IS 3025 (Part 40), 2019	11.2	75	200
7.	Chloride, mg/L, Max	IS 3025 (Part 32), 2019	6.99	250	1000
8.	Magnesium as Mg, mg/l	APHA 24 th Ed -3500-Mg Method B:2023 (Calculation Method)	5.83	30	100
9.	Colour, Hazen, Max	IS 3025 (Part 4): 2021	Less than 5	5	15
10.	Odour	IS 3025 (Part 5) : 2018	Agreeable	Agreeable	Agreeable

Note:

1. The results listed refer only to tested sample and applicable parameters.
2. This certificate is not to be reproduced wholly or in parts for promotional publicity or legal purpose without permission of authority of testing laboratory.
3. The samples will be destroyed after 15 days from the date of issue of test certificate, unless otherwise agreed with customer.
4. The results apply to the sample as received
5. The Laboratory is responsible for all the information provided in the report, except when information is provided by the customer

**** End of Report****

Review and Authorized By

(Er. Mukesh Kumar)
Technical Manager, Lab
District Water Quality Testing
Monitoring Laboratory
Uttarakhand Jal Sansthan, U.S. Nagar

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.

Dated: 22.09.2025

It is certified that an inspection team headed by Mr. MUKESH KUMAR (A.E. UTS RUDRAPUR)

(Name of Officers with designation) from U.T.S. RUDRAPUR PHED

inspected the GURUKUL ACADEMY, Sitarganj Road, Jhankot - Khatima

(Name & Address of the school) on 22.09.25 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. 27/UTS/DLWOTML/2025-26 dated 22.09.25

of DLWOTML UTS RUDRAPUR (PHED Lab) certified that the

GURUKUL ACADEMY, Khatima (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till 01 year

Signature with Seal:

Name

Designation

Name & Address of the Office / Department : UTS: Rud

अभिजाती अभियन्ता
Mr. MUKESH KUMAR
Assistant Engineer

To

GURUKUL ACADEMY
Sitarganj Road, Jhankot - Khatima
(Name & Address of the Institution)

अभिजाती अभियन्ता
उत्तराखण्ड जल संस्थान
ऊष्म सिंग नगर

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies